

A04



A03 № 3130041371 / 2024.05.10

page 1 of 1

A01 HUS LTD

1 Industrialna Str.
3600 Lom, Bulgaria

A02 Inspection certificate EN 10204 / 3.1

B01 Cold formed welded structural hollow sections of non-alloy
and fine grain steels БДС EN 10219-2

A07	Order №
A06	Customer.....SZATMARI KFT
A10	Invoice № 3130041371

B02	EN 10219-1 S235JRH	
B09	CFRHS	option 1.1 ; 1.4
B09		

B11 2 556 m.

B13

B09	CFRHS 60x60x3	B10	6000 mm.	B11	294 m.	B13		B06	0003689011989	B07	824113
B09	CFRHS 60x60x3	B10	6000 mm.	B11	294 m.	B13		B06	0003689019989	B07	1214146
B09	CFRHS 40x40x3	B10	6000 mm.	B11	294 m.	B13		B06	0003673830989	B07	614186
B09	CFRHS 40x40x3	B10	6000 mm.	B11	294 m.	B13		B06	0003673909989	B07	724192
B09	CFRHS 40x40x3	B10	6000 mm.	B11	294 m.	B13		B06	0003673882989	B07	614186
B09	CFRHS 100x60x4	B10	6000 mm.	B11	294 m.	B13		B06	0003617586989	B07	813534

C71 Chemical composition %

B06	B07	C	Mn	Si	P	S	Al	Cu	Cr	Ni	Mo	Ti	Nb	N	CEV 2
Bundle №	Heat №	x100				x1000				x100				x100	
000368901198910	824113	11	37	2	19	25								8	18
000368901998910	1214146	12	41	2	25	25								9	20
000367383098920	614186	10	39	1	21	25								8	18
000367390998920	724192	12	39	1	18	25								8	19
000367388298920	614186	10	39	1	21	25								8	18
000361758698910	813534	11	40	2	25	22								9	19

B07	C51 Mechanical properties				
Heat №	C00	C11			
	Certificate №	Test №	ReH	Rm	A
			MPa	MPa	%
824113	510476	46285-1	279	368	36
1214146	510418	46571-6	294	407	29
614186	515016	410240-10	275	382	31
724192	514673	49986-11	275	412	30
614186	515016	410240-10	275	382	31
813534	550222	428905-5	260	407	40

D02 Non-destructive testing - passed.


Z02 Z03 Director Branch Lom

N.Dechev

Date 10.05.2024

Seal HUS LTD.

www.husltd.com



Z04



1938

17

1938-CPR-0285/2

A05 AK

D01 The test has been performed on the provided products and the results are satisfactory.

Z01 The producer declares that the product is according to the customer's order.

Z05 Without any post heat treatment; with shape, dimensions and tolerances according БДС EN 10219-2; performance characteristics according appendix ZA.1 of the product standart. Function - for steel structures and combined steel and reinforced concrete structures.

Z06 Claims are allowed within 14 days from product receipt. In order to consider a claim, the customer must provide a quality inspection control document and a marking on the claimed goods. Claims associated with unloading and storage of the goods will not be accepted.

Z07 Declaration of performance №3130041371HUS CFRHS S235JRH /2024